Certificate of constancy of performance



Institut für Baustoffe, für das Bauwesen

Massivbau und Brandschutz

Materialprüfanstalt

🛚 DAkkS

Akkreditierungsstell D-ZE-11267-01-00

0761-CPR-240031-2.7

Z-MPA-BS-240031 (no. of agreement)

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Product Regulation or CPR), this certificate applies to the

construction product

Powered smoke and heat exhaust ventilator with the trade name: 'RWM 57' Not classified: 600 °C / 120 min

in the designs

RWM 57-2528, RWM 57-3540, RWM 57-4045, RWM 57-4550, RWM 57-5056, RWM 57-5663, RWM 57-6371, RWM 57-7180, RWM 57-8090

produced by or for

Nicotra Gebhardt GmbH Gebhardtstraße 19-25 74638 Waldenburg Germany

in the manufacturing plant

Waldenburg (Germany).

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 12101-3:2015

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was issued 2025-01-01 and will remain valid until 2029-12-31, as neither the harmonised standard, the construction product, the AVCP method nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the product certification body. The certificate was first issued on 2025-01-01.

Braunschweig

Dr.-Ing. Sven Lehmberg (Head of certification body)

Materialprüfanstalt für das Bauwesen (MPA BS) | Beethovenstr. 52 | D-38106 Braunschweig