

Herewith it is confirmed to the company

Nicotra-Gebhardt GmbH

D-74638 Waldenburg

for the operated fan test rig of test category H according to test and certification program TÜV SÜD Industrie Service GmbH for fan test rigs version 3/2015-08

"Kleiner Kammer-Prüfstand Typ 1580"

located in D-74638 Waldenburg

for the volumetric flow range of 200 m³/h to 12,000 m³/h and a pressure range up to 5,000 Pa,

based on the positive results of the completed tests regarding compliance with the requirements of the Standard **DIN EN ISO 5801:2018-04**

to identify this with the following TÜV SÜD Certification Mark.



This certificate is valid until 2026-03-31

Certificate Registration Number: 10/11/08



Certification Body for Products Refrigeration and Air-Conditioning Munich, 2024-03-25

